

**ADDENDUM NO. 1, DATED OCTOBER 14, 2022**

TO

**TOWNSHIP OF MORRIS**  
MORRIS COUNTY, NEW JERSEY

**WOODLAND SEWAGE TREATMENT  
PLANT INTERNAL RECYCLE  
SYSTEM IMPROVEMENTS**

CONTRACT NO. 71  
OTE: 2022-02



---

**DAVID L. KLEMM**

Professional Engineer - NJ Lic. No. 38672

**M**  
**M**  
MOTT  
MACDONALD

**RECEIPT ACKNOWLEDGEMENT**

FOR

**ADDENDUM NO. 1, DATED OCTOBER 14, 2022**

TO

**TOWNSHIP OF MORRIS**  
MORRIS COUNTY, NEW JERSEY

**WOODLAND SEWAGE TREATMENT  
PLANT INTERNAL RECYCLE  
SYSTEM IMPROVEMENTS**

CONTRACT NO. 71  
OTE: 2022-02

RECEIVED BY: \_\_\_\_\_ DATE: \_\_\_\_\_  
(Signature)

\_\_\_\_\_  
(Print Name)

COMPANY: \_\_\_\_\_

Return via email to Mott MacDonald at [David.klemm@mottmac.com](mailto:David.klemm@mottmac.com)

**Township of Morris  
Morris County, New Jersey**

**WOODLAND SEWAGE TREATMENT PLANT INTERNAL RECYCLE  
SYSTEM IMPROVEMENTS**

**Contract No. 71  
OTE: 2022-02**

**Addendum No. 1**

*October 14, 2022*

---

**TO ALL CONCERNED:**

The original Contract Documents dated September 2022 for the above referenced contract are amended as noted in this Addendum No. 1. This addendum shall become part of the Contract Documents and is attached thereto:

**A. Concerning the Contract Specifications:**

**1. BID SECTION**

Part B of the Bid Document Submission Checklist on page B-41 shall be revised to eliminate requirement to submit a Maintenance Bond. Page B-41 to be replaced with the attached revised page B-41.

**B. Concerning the Drawings:**

**1. G-002**

ADD Note 14 under General Notes as follows: "14. The Owner will take one (1) Oxidic Tank train (i.e. consisting of Tanks A-1 through A-4) off-line at a time to allow for the construction of the work in the first Oxidic Tank train. Following construction of work in the first Oxidic Tank train the Owner will take the second Oxidic Tank train (i.e. consisting of Tanks B-1 through B-4) off-line to allow for construction of work in the second Oxidic Tank train. See Special Information for Bidders in Contract Specifications for additional details."

ADD Note 15 under General Notes as follows: "15. The Owner will dewater the Oxidic Tanks by gravity and hose down tanks (one tank train at a time). Following hose down cleaning by Owner and prior to construction, the Contractor shall remove any standing water, debris, etc. remaining in Oxidic Tanks as required to complete construction of Contract work."

**2. P-001**

The material of the existing 1-1/4" service water piping to be modified is galvanized. New service water piping to be provided to modify the service water system shall also be galvanized. The existing spray nozzles shall be relocated (re-used) and installed on the modified service water piping as shown on the Plans.

**3. P-002 & P-003**

To clarify, heat tracing and insulation on the 12-inch pipe shall be provided for all exposed pipe located on the exterior of the Oxidic Tanks as shown on the Lower Level Plan and Sections 1 & 2 (no change). Heat tracing and insulation does NOT extend to exposed pipe located within the Oxidic Tanks.

**4. P-005**

Detail D – Pipe Wall Support Detail – To confirm, pipe supports shall be electro-galvanized as per Note 1 as shown on the Contract Drawings (no change).

Detail E – Trapeze Roller Hanger Pipe Support - To confirm, pipe supports shall be stainless steel as per Note 1 as shown on the Contract Drawings (no change).

**5. P-006**

Detail K – Flange Pipe Support Detail - Pipe supports shall be electro-galvanized.

Detail M – Typical Metal Pipe Support Details - Pipe supports shall be electro-galvanized.

\* \* \* \* \*

**BID DOCUMENT SUBMISSION CHECKLIST  
TOWNSHIP OF MORRIS OF COUNTY OF MORRIS**

WOODLAND SEWAGE TREATMENT PLANT  
INTERNAL RECYCLE SYSTEM IMPROVEMENTS  
OTE-2022-02  
CONTRACT NO. 71

**A. Failure to submit the following documents is a mandatory cause for the bid to be rejected.  
(N.J.S.A. 40A:11-23.2)**

Initial Each Item Submitted With Bid  
(Township of Morris checkmarks)

(Bidder's  
initials)

<b>X</b>	Statement of Ownership Disclosure pursuant to NJSA 52:25-24.2	
<b>X</b>	Acknowledgement of Receipt of Addenda (to be completed if addenda are issued)	
<b>X</b>	EEO Compliance*	
<b>X</b>	Bid Guarantee (bid bond or certified/cashier's check) pursuant to NJSA 40A: 11-21	
<b>X</b>	Consent of Surety (certificate from surety company) pursuant to NJSA 40A: 11-22	
<b>X</b>	Listing of Subcontractors as required by NJSA 40A:11-16	
<b>X</b>	Public Works Contractor Registration, copies of the general contractors and top four specialty subcontractors certificates or certificate applications	
<b>X</b>	Disclosure of Investment Activities in Iran	
<b>X</b>	For joint venture bidders, separate Ownership Disclosure Statements are included in the Bid (Pages for each member (N.J.S.A. 52:25-24.2))	

**B. Failure to submit the following documents may be a cause for the bid to be rejected.  
(N.J.S.A. 40A:11-23.1b.)**

Initial Each Item Submitted With Bid  
(Township of Morris checkmarks)

(Bidder's  
initials)

<b>X</b>	Business Registration Certificate*	
<b>X</b>	Submission of Non-Collusion Affidavit (this form must be notarized)	
<b>X</b>	Performance Bond	
	Labor and Material (Payment) Bond	
	Maintenance Bond as required by <u>N.J.S.A. 40A:11-16.3b</u>	
<b>X</b>	Equipment Certification	
<b>X</b>	Debarred List Affidavit	
<b>X</b>	Certificate of Insurance & Hold Harmless Agreement	
<b>X</b>	Bid Proposal Form	
<b>X</b>	Statement of compliance with NJSA 45:C-2(h) (licensed master plumber)	
<b>X</b>	Bid is legally executed on behalf of the bidder	
<b>X</b>	Prices for each bid item contained in the Bid forms	
<b>X</b>	Prices in words and numbers as may be modified to correct discrepancies (or omissions) inserted for each Bid Item in Bid	
<b>X</b>	Total Price bid as may be modified to correct discrepancies in the individual bid amounts inserted in Bid in words and numbers	
<b>X</b>	Details of bid security inserted in Bid Pages	
<b>X</b>	Signature of Bidder on Bid is witnessed	
<b>X</b>	Names of signers and witnesses are typed or printed below signatures	
<b>X</b>	Corporate acknowledgment on Certificate of Surety and evidence of authority of the signer is attached to Certificate of Surety (N.J.S.A. 40A:11-22 and N.J.S.A.	